

## Mach™ Tripoint®

Hybrid energy powered 0.5 gpf urinal flushometer K-10UH00G20

### Features

- 0.5 gpf (1.9 lpf).
- Activation distance is factory-set.
- Chloramine and chlorine resistance on all rubber components exposed to waterway.
- Engineered for optimal performance with KOHLER® commercial fixtures.
- 125-micron filter protects internal components.
- High back pressure vacuum breaker.
- Locking stop cap provides protection against vandalism.
- No external flush volume adjustment ensures water conservation.
- 24-hour automatic sentinel flush keeps trapway fresh.
- Mechanical override enables flushometer to be used manually even during a power outage.
- Powered by a 30 year/875,000 cycle hybrid energy cell.

### Material

• Brass construction with durable Polished Chrome finish.

### Technology

- Electronic infrared sensor with Tripoint® technology for accurate activation.
- Patented piston technology for superior flush volume accuracy.

### Installation

 Intended for urinal installations with 3/4" (19 mm) top spud coupling connection.

### **Recommended Products/Accessories**

K-23723 Faucet cleaner





### **Codes/Standards**

ASME A112.18.1/CSA B125.1 ASSE 1037/ASME A112.1037/CSA B125.37 EPA WaterSense® ADA ICC/ANSI A117.1 CSA B651 OBC

# KOHLER<sup>®</sup> One-Year Limited Warranty

See website for detailed warranty information.

### **Available Colors/Finishes**

Color tiles intended for reference only.

**Color Code Description** 


CP Polished Chrome



### Mach<sup>™</sup> Tripoint<sup>®</sup>



Hybrid energy powered 0.5 gpf urinal flushometer K-10UH00G20



### **Technical Information**

All product dimensions are nominal.

### Pressure/fixture Supply Requirements

Fixture pressure<br/>max (static):80 psi (551.6 kPa)Fixture pressure min<br/>(static):25 psi (172.4 kPa)Min flowing<br/>pressure:25 psi (172.4 kPa)Min flow rate:25 gpm (94.6 lpm)

#### Notes

Install this product according to the installation instructions.

ADA, OBC, CSA B651 compliant when installed to the specific requirements of these regulations.

